



D.A.V. PUBLIC SCHOOL

SECL, Bhatgaon Area, Distt: Surajpur (C.G.) Pin – 497235

☎ 07775-299461(O), Mob. 9424260389, 799901716

E-mail : davbhatgaon@gmail.com, Website: www.davbhatgaon.org.

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Date: 04/08/25

It is certified that an inspection team headed by Chemist of PHED.
(Name of Officers with designation) from Surajpur PHED inspected
the D.A.V. Public School SECL Bhatgaon (Name & Address of the
school) on 01/08/2025 (date of inspection) and on the basis of Water Test
Report (Attached) bearing no 343 dated
01/08/2025 of Surajpur (PHED Lab) certified that the
D.A.V. PUBLIC SCHOOL SECL BHATGAON (Name of school)
has safe drinking water facilities for the students and members of staff of the institution.
School is also maintains the hygienic sanitation condition in the school building & the
campus as per norms prescribed by the Central State/ U.T. Govt.

This certificate is valid till 1 year.

Signature with Seal
Name Navin Kumar Das
Designation Chemist
Name & Address of the Office /
Department PHED - Surajpur

To Principal
D.A.V. Public School, Bhatgaon
(Name & Address of the Institution)

Principal
D.A.V. Public School
Bhatgaon, Surajpur (C.G.)
Pin-497235

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies

कार्यालय, सहायक अभियंता

लोक स्वास्थ्य यांत्रिकी उपखण्ड-सूरजपुर, जिला-सूरजपुर (छ0ग0)

पत्र क्रमांक ३५२/ज.परी.प्र./स.अभि./लो.स्वा.यां.उपखण्ड/सूरजपुर, दिनांक :- ०५.०७.२०२५
प्रति,

प्राचार्य
डी.ए.व्ही.पब्लिक स्कूल
भटगांव, जिला-सूरजपुर (छ0ग0)

विषय :- जल परीक्षण के संबंध में ।

संदर्भ :- आपका पत्र क्र. DAV/Bhat/25-26/167

Date- 30.07.2025

—00—

उपरोक्त संदर्भित विषयान्तर्गत लेख है कि आपके द्वारा 01 नग जल नमूना परीक्षण हेतु लाया गया था। उक्त जल नमूने का परीक्षण कर परीक्षण प्रतिवेदन तैयार कर आपकी ओर आवश्यक कार्यवाही हेतु सादर प्रेषित है।

सहपत्र:- जल नमूने का जल परीक्षण प्रतिवेदन ।

केमिस्ट/प्रयोगशाला इन्चार्ज
जिला जल परीक्षण प्रयोगशाला
सूरजपुर, जिला-सूरजपुर(छ0ग0)

पृ क्रमांक / ज.परी.प्र./स.अभि./लो.स्वा.यां.उपखण्ड/सूरजपुर, दिनांक :- ०५.०७.२०२५
प्रतिलिपि :-

1. कार्यपालन अभियंता, लोक स्वास्थ्य यांत्रिकी विभाग सूरजपुर की ओर सूचनार्थ हेतु संप्रेषित।

07/08/2025
PRINCIPAL
D.A.V. Public School
Bhatgaon, Surajpur (C.G.)
Pin-497235

केमिस्ट/प्रयोगशाला इन्चार्ज
जिला जल परीक्षण प्रयोगशाला
सूरजपुर, जिला-सूरजपुर(छ0ग0)

DISTRICT WATER TESTING LABORATORY (National Drinking Water Mission)

Public Health Engineering Department, Division-Surajpur, Ketka road, Surajpur Distt-Surajpur (C.G.)

District- Surajpur Samples

- (i) Date of Collection- 31.07.2025
(ii) Date of Received- 31.07.2025
(iii) Date of Analysis - 01.08.2025

Details of Source & Location-

D.A.V. Public School SECL,

Bhatgaon Area, Distt.: Surajpur (C.G.)

(i) Water sample- D.A.V. Public School Bhatgaon

(No of Sample-01)

Ref.No. D.A.V./Bhat./2025-26/167

Date:-30.07.2025

Note-Water sample brought by School Staff.


Ref.No. D.A. V./Bhat/2020-21

Note-Water sample brought by School Staff.

| S No | Characteristics | Unit Table | Acceptable | Cause of rejection | Results | | | | |
|-------------------------|--|-----------------|-----------------|--------------------|---------|------|-------|------|-----|
| | | | | | (i) | (ii) | (iii) | (iv) | (v) |
| PHYSICAL | | | | | | | | | |
| | | N.T.U | 1.0 | 5.0 | 8.0 | | | | |
| 1 | Turbidity | Pt Cobalt Scale | 5.0 | 15 | 1.0 | | | | |
| 2 | Colour | - | Unobjectionable | objectionable | Agr. | | | | |
| 3 | Taste | - | Unobjectionable | objectionable | Agr. | | | | |
| 4 | Odour | | | | | | | | |
| Chemical | | | | | | | | | |
| 5 | pH | pH Scale | 6.5 to 8.5 | <6.5 or >8.50 | 6.677 | | | | |
| 6 | Total Alkalinity | mg/l | 200 | 600 | 76.84 | | | | |
| 7 | Chlorides | mg/l | 250 | 1000 | 25.812 | | | | |
| 8 | Nitrates | mg/l | 45 | 45 | 0.00 | | | | |
| 9 | Total Hardness (as CaCO ₃) | mg/l | 200 | 600 | 80.16 | | | | |
| 10 | Calcium (as ca) | mg/l | 75 | 200 | 16.86 | | | | |
| 11 | Magnesium (as Mg) | mg/l | 30 | 100 | 9.138 | | | | |
| 12 | Iron | mg/l | 0.1 | 1.0 | 0.00 | | | | |
| 13 | Fluorides | mg/l | 1.0 | 1.5 | 0.011 | | | | |
| 14 | Total dissolved Solids | mg/l | 500 | 2000 | 165.00 | | | | |
| 15 | Residual Chlorine | mg/l | 0.2 | 1.0 | 0.00 | | | | |
| BACTERIOLOGICAL- | | | | | | | | | |
| 16 | Coli form organisms At 37° C | M.P.N/ 100ml | 24 Hrs | | -ve | | | | |
| | | | 48 Hrs | | -ve | | | | |

REMARK -


 07/08/2025
PRINCIPAL
 D.A.V. Public School
 Bhatgaon, Surajpur (C.G.)
 Pin-497235


 In charge/Chemist
 Water Testing Laboratory
 P.H.E. Sub Division
 Surajpur (C.G.)

-----End of Report-----